



City of Richmond

February 23, 2011
File: 02-0775-50-4215/Vol 01

Business and Financial Services Department
Finance Division
Telephone: 604-276-4218
Fax: 604-276-4162

Attention: To All Bidders

Dear Madame/Sir:

Re: Request for Quotation 4215Q – Supply and Installation of Piles at Garry Point Park - Addendum One (1)

This Addendum includes items of clarification; forms part of the Contract Documents and shall be read, interpreted and coordinated with all other parts. Please review and consider the following information in the preparation of your Quotations:

I. Questions and Answers:

- Q.1 Ref: Part C – Section 3.2 Steel Pipe – Clause d) - The specification calls for the pipe to be shop primed in accordance with CISC/CPMA-2-73a “Quick Dry Primer”. The CISC/CPMA Standard for Quick-Dry Primer is 2-75. The CISC/CPMA Standard 1-73a is for a “Quick-drying One-coat Paint”. I could not find a 2-73a standard. Please clarify which standard is to be used.
- A.1 CISC/CPMA Standard 2-75 should be used.
- Q.2 Do you have more specific information regarding the type of marine grade, self-priming, immersion approved epoxy paint?
- A.2 Please see the specification sheet appended to this Addendum.
- Q.3 What colour are the piles to be painted?
- A.3 The piles are to be painted in a grey colour (KHA302) or equivalent.
- Q.4 Are the piles to be coated full length or to some minimum distance below the mud line?
- A.4 The piles are to be coated to the 60'-0 length leaving approx. 20'-0 of unpainted surface.
- Q.5 What size/type of zinc anodes do you want for the cathodic protection?
- A.5 This question will be addressed in a second addendum to be issued before the revised Closing Date.

II. Closing Date Extension:

Please be advised that the Closing Date has been extended as follows:

WAS: Friday, February 25, 2011; 3:00 pm, local time.

IS NOW: Friday, March 4, 2011; 3:00 pm, local time.

Bidders must sign and include this Addendum with their submission.

Signature, Name and Title

Yours truly,

Kerry Lynne Gillis
Buyer 2

KG:kg

pc: Marcus Liu, Engineering Technologist,
Parks Division