



# City of Richmond

March 1<sup>st</sup>, 2011

File: 02-0775-50-4215/Vol 01

**Business and Financial Services Department**

Finance Division

Telephone: 604-276-4218

Fax: 604-276-4162

**Attention: To All Bidders**

Dear Madame/Sir:

**Re: Request for Quotation 4215Q – Supply and Installation of Piles at Garry Point Park -  
Addendum Two (2)**

This Addendum includes items of clarification; forms part of the Contract Documents and shall be read, interpreted and coordinated with all other parts. Please review and consider the following information in the preparation of your Quotations:

I. Questions and Answers:

Q.1 What size/type of zinc anodes do you want for the cathodic protection?

A.1 The zinc anodes are a hanging type, cylindrical in shape at 60 inches long x 3 inches wide x 30lbs (or equivalent length and width with squared edges). They shall be hung from the pile top with steel cable allowing them to be inspected and/or changed out without the use of divers. The cable extends from the top connection to the anode. Please see the detail, appended to this Addendum.

Bidders must sign and include this Addendum with their submission.

---

**Signature, Name and Title**

Yours truly,

Kerry Lynne Gillis  
*Buyer 2*

KG:kg

pc: Marcus Liu, Engineering Technologist,  
Parks Division


# ANODE DETAIL

GARRY PT. FLOAT


PILES

FEB 24/11

SD.



TYPICAL FOR ALL PILES  
CATHODIC PROTECTION DETAIL  
N.T.S.



CABLE CLAMP DETAIL  
1:5