



City of Richmond

July 19, 2011
File: 02-0775-50-4342/Vol 01

Business and Financial Services Department
Finance Division
Telephone: 604-276-4218
Fax: 604-276-4162

Attention: To All Proponents

Dear Madame/Sir:

**Re: 4342P Request for Proposal - Design Services for Montrose Sanitary Pump Station–
Addendum # 1**

This Addendum includes items of clarification, forms part of the Contract Documents and shall be read, interpreted and coordinated with all other parts. Please review and consider the following information in the preparation of your Proposals:

I. Questions and Answers

Q.1 Does the new forcemain discharge into an existing manhole or connect to an existing forcemain on No. 3 Road?

The new forcemain will connect into the existing forcemain on No. 3 Road

Q.2 Is there three (3) phase powers on No. 3 Road close to the proposed pump station site?

The existing Montrose Sanitary Pump Station is currently running on three (3) phase power.

Q 3. Section G – Additional Consultation Services. Does the one hundred and sixty (160) hours allocated in Item v. for Professional engineering advisory service during construction; include all of the items in Section G or for professional engineering advisory services only?

The 160 hours is only for the professional engineering advisory services during construction, and is in addition to the other services identified in Section G.

Q.4 The bid tender document states "pre-purchased" equipment. Can you please confirm if the electrical kiosk has already been purchased for the subject line project? Or does the City of Richmond plan to purchase the kiosk direct from a supplier or from a general contractor.

The City of Richmond will purchase a kiosk from a supplier, which follows the specifications and details prepared by the successful proponent of this contract. The general contractor for the forcemain and pump station construction will then install the pre-purchased kiosk.

II. Deadline Extension

The deadline date for the submission of the RFP has now been changed. The dead line time and date is now 3:00pm local time, on **Thursday July 28, 2011**.

Bidders must sign and include this Addendum with their submission.

Signature, Name and Title

Yours truly,

Daianna Panni
Buyer 1

DP:dp

pc: Anthony Fu, P.Eng. Project Engineer