



# City of Richmond

May 21, 2013  
File: 02-0775-50-4731/Vol 01

**Finance and Corporate Services Department**  
Finance Division  
Telephone: 604-276-4218  
Fax: 604-276-4162

**Attention: To All Tenderers**

Dear Sir/Madame:

**Re: Contract T.4731 – Montrose Sanitary Pump Station Upgrade – Addendum Three**

This Addendum includes items of clarification, forms part of the Contract Documents and shall be read, interpreted and coordinated with all other parts. Please review and consider the following information in the preparation of your Tenders:

**I. Questions and Answers:**

1. Is your water works supplier supplying water pressure transducer? If not we need spec on this unit.

*Ametek (0 to 300psi Pressure Range) Submersible Transducer to be supplied and installed by the Contractor.*

2. What size is standby generator city is supplying? We need this to know what size of wires to supply kiosk with.

*50kw*

3. Does well hatch have an intrusion alarm? If so who is supplying?

*No*

**NOTE: the City reserves the right not to answer any inquiries received after the issue of this Addendum.**

**II. Extension to Contract Time:**

Please be advised that the project completion date has been extended:

WAS: August 30, 2013  
IS NOW: September 30, 2013

Yours truly,

A handwritten signature in black ink, appearing to be 'Kerry Lynne Gillis', written in a cursive style.

Kerry Lynne Gillis  
*Buyer 2*

KG:kg

pc: Anthony Fu, Project Engineer