



City of Richmond

November 15, 2013
File: 10-6340-20-P.11201/Vol 01

Engineering
Telephone: 604-276-4289
Fax: 604-276-4197

TO THOSE WHO HAVE RECEIVED COPIES OF T.4809

Dear Sir/Madam:

**Re: Contract T.4809
Addendum No. 2
No.6 Road Widening – Westminster Hwy to Commerce Parkway**

This addendum forms part of the Contract Documents and shall be read, interpreted and coordinated with all other parts. The costs of all work contained herein shall be included in the Contract Price. The following revisions supersede the information contained in the original Contract Document to the extent referenced and shall become part thereof.

Tenderers shall acknowledge receipt of this addendum by inserting its number and date where provided for on the Form of Tender.

1. QUESTIONS RECEIVED FROM CONTRACTOR & SUBSEQUENT ANSWERS

1. Q: Has consideration been given regarding the potential damage to the trees on the West side of the road that will occur during paving of the walkway?
A: The Contractor will need to protect the existing trees from being damaged during construction.
2. Q: Can you identify what you will expect as a temporary ramping from the existing pavement down to the asphalt we will pave on the widening of #6 Rd? Will you expect to see a paved ramp or would you require the lip to be milled off? And if paved, how wide, and tar papered or permanent?
A: The Contractor will be required to ramp any perpendicular edges to the curb with a minimum 1m transition, any parallel edges will require a 0.5m transition. The paving is to be permanent.
3. Q: Are Inserta Tee's acceptable in lieu of manufactured wye's.
A: Yes

Sincerely,

Mile Racic
Engineering & Public Works